

# Kidde Recalls Dual Sensor Smoke Alarms Due to Risk of Failure to Alert Consumers to a Fire

**Name of product:**

Kidde dual-sensor (photoelectric and ionization) smoke alarms – models PI2010 and PI9010

**Hazard:**

A yellow cap left on during the manufacturing process can cover one of the two smoke sensors and compromise the smoke alarm's ability to detect smoke, posing a risk of consumers not being alerted to a fire in their home.

**Remedy:**

Replace

**Recall date:**

**March 21, 2018**

**Units:**

**About 452,000 in the U.S. (In addition, about 40,000 were sold in Canada.)**

**Consumer Contact:**

Kidde toll-free at 833-551-7739 from 8:30 a.m. to 5 p.m. ET Monday through Friday, from 9 a.m. to 3 p.m. on Saturday and Sunday, or online at [www.kidde.com](http://www.kidde.com) and click on "Product Safety Recall" for more information.

See attached photos of affected detectors. Contact the Valparaiso Volunteer Fire Department at 729-5410 with any questions or concerns...

